



Number	KIP-15900/G	Scope	Regulation (EU) 2016/426
Issue date	03-08-2018	Module	B
Expire date	02-08-2028		
PIN	0476CQ1097	Report	141201097/4
Replaces	—	Page	1 of 1

EU TYPE-EXAMINATION CERTIFICATE

Kiwa Cermet Italia declares that the products type:

Central heating condensing boilers

Trade mark: **COSMOGAS**

Models: MYDENS 15P, MYDENS 15C, MYDENS 15B, MYDENS 24P, MYDENS 24C, MYDENS 24B, MYDENS 34P, MYDENS 34C, MYDENS 34B, MYDENS 60A, MYDENS 60C

Placed on the market by **COSMOGAS S.r.l.**
Via L. Da Vinci 16, 47014 Meldola (FC) Italy

meet the essential requirements as described in the
Regulation (EU) 2016/426 relating to appliances burning gaseous fuels.

Appliance type: B₂₃, B_{23P}, C₁₃, C₃₃, C₄₃, C₅₃, C₆₃, C₈₃, C₉₃
C_{13X}, C_{33X}, C_{43X}, C_{53X}, C_{63X}, C_{83X}, C_{93X}

Countries: AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV, MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

Related to the following gas groups:

Group	mbar
E	20
H	20;25
L	25

Group	mbar
LL	20
Esi	20/25
E(S)	20

Group	mbar
E(R)	20
B/P	30; 37; 50
P	30; 37; 50
M	20

The above gas groups can be combined according to the standard EN437:2009 and national situation of countries.

The assessment test have been performed using the following standards as guidelines:

EN 15502-1:2012+A1:2015
EN 15502-2-1:2012+A1:2016

The validity of this certificate can be verified on request at the following e-mail address: info@kiwa.it
This certificate will expire if there have been any changes to the product that may have an impact on compliance with the requirements of the Directive. This certificate will expire if there have been any updates and / or changes to the Technical Standards applicable unless specifically approved by Kiwa Cermet Italia.

Chief Operating Officer
Giampiero Belcredi



SGQ N° 007A
SGA N° 010D
PRD N° 069B
FSM N° 004I
PRS N° 089C

